



Certificate of constancy of performance

0402 - CPR - SC0517-15

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Emergency exit devices operated by a lever handle or a push pad as specified in appendix to this certificate, for doors on escape routes

Product name: as specified in appendix to this certificate

produced by or for

ASSA AB
Kungsgatan 71
SE-631 05 Eskilstuna
Sweden

and produced in the manufacturing plants

Manufacturing site 5

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard

EN 179:2008

under system 1 for the performances set out in this certificate are applied and that

the construction product fulfils all the prescribed requirements for these performances.

This certificate was first issued on 2015-12-16 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

2015-12-16

SP Technical Research Institute of Sweden
Certification, Notified Body No. 0402

Lennart Månsson
Certification Manager

Per Adolfsson
Certification officer

SP Technical Research Institute of Sweden

Box 857, SE-501 15 Borås, Sweden

Phone: +46 10-516 50 00

E-mail/internet: info@sp.se/www.sp.se

4P05468

This is issue 1.

Swedish Notified Bodies are appointed by SWEDAC (the Swedish board for Accreditation and Conformity Assessment) under the terms of Swedish legislation. This certificate may not be reproduced other than in full, except with the prior written approval by SP. This certificate is issued in a Swedish and an English version.

Certificate of constancy of performance

0402 - CPR - SC0517-15 appendix

Emergency exit device operated by a lever handle or a push pad

for doors on escape routes

Max door width 1320 mm, max door height 2520 mm, max door weight 200 kg

Product:

Emergency exit device	Operated by a lever handle (type A)/a push pad (type B)	Lock case
179A/AT/F	type A	710-50/70, 721-50/70, 722-50/70, 727-50/70
179B/BT/G	type A	711-50/70*, 732-50/70
179A/AT/F S4	type A	710-35, 721-35, 722-35, 727-35
179B/BT/G S4	type A	711-35*, 732-35
179E-2	type A	EL580-50/70, EL587-50
179 S3	type A	1361-28, 1361S-28
179/8563	type A	8561-50, 8562-50*

*) The fire/smoke door must be equipped with another product that keeps the door closed in case of fire

Performance/Classification:	Product	
	All emergency exit devices Lock case 711 excluded	Emergency exit devices with lock case 711 or 8562
4.2.1 Ability to release (for doors on escape routes)	Pass (type A, ≤ 70 N unloaded)	Pass (type A, ≤ 70 N unloaded)
4.2.1 Durability of ability to release against aging and degradation (for doors on escape routes)	Pass (100 000 cycles)	Pass (100 000 cycles)
4.2.1 Self closing ability C (for fire/smoke doors on escape routes)	C	Not relevant
4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes)	Pass (100 000 cycles)	Not relevant
4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire/smoke doors on escape routes)	Grade B	Grade B, when used with other product that keeps the door closed in case of fire
4.1.29, ZA.1 Control of Dangerous substances	Declared by the manufacturer	Declared by the manufacturer