



Certificate of constancy of performance

0402 - CPR - SC0518-15

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Panic exit devices operated by a horizontal bar, for use on escape routes
as specified in appendix to this certificate

Product name: 1125, 1125:1, 1130, 1130:1

produced by or for

ASSA AB
Kungsgatan 71
SE-631 05 Eskilstuna
Sweden

and produced in the manufacturing plants

Manufacturing site 5

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard

EN 1125:2008

under system 1 for the performances set out in this certificate are applied and that

the construction product fulfils all the prescribed requirements for these performances.

This certificate was first issued on 2015-12-16 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

2015-12-16

SP Technical Research Institute of Sweden
Certification, Notified Body No. 0402

Lennart Månsson
Certification Manager

Per Adolfsson
Certification officer

Certificate of constancy of performance

0402 - CPR - SC0518-15 appendix

Panic exit device operated by a horizontal bar

for doors on escape routes

Max door width 1320 mm, max door height 2520 mm, max door weight 200 kg

Product:

Panic exit device	Lock case	Note
1125	761-50/70, 762-50/70, 767-50/70, 772-50/70	-
1125:1	-	Only for use on the inactive leaf of a double doorset
1130	761-35/50/70, 762-35/50/70, 767-35/50/70, 772-35/50/70	-
1130:1	-	Only for use on the inactive leaf of a double doorset

Performance/Classification:	Product	
	<i>1125, 1130</i>	<i>1125:1, 1130:1</i>
4.2.1 Ability to release (for doors on escape routes)	Pass (≤ 80 N unloaded, ≤ 220 N loaded)	Pass (≤ 80 N unloaded, ≤ 220 N loaded)
4.2.1 Durability of ability to release against aging and degradation (for doors on escape routes)	Pass (100 000 cycles, ≤ 50 N)	Pass (10 000 cycles, ≤ 50 N)
4.2.1 Self closing ability C (for fire/smoke doors on escape routes)	C	C
4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes)	Pass (100 000 cycles)	Pass (10 000 cycles)
4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire/smoke doors on escape routes)	Grade B	Grade B
4.1.29, ZA.1 Control of Dangerous substances	Declared by the manufacturer	Declared by the manufacturer